



SEP 23 2004  
640 cust\_id  
246199 insp\_id  
7221 site\_id

**INSPECTION REPORT**

**COVANCE LABORATORIES INC**

**Customer ID: 640**

**Certificate: 35-R-0030**

**3301 KINSMAN BOULEVARD  
MADISON, WI 53704**

**Site: 001**

**COVANCE LABORATORIES, INC.**

**Inspection**

**Type: ROUTINE INSPECTION**

**Date: SEP-01-2004**

**3.75 (c)(2)**

**HOUSING FACILITIES, GENERAL.**

c) Surfaces

.....(2) Maintenance and replacement of surfaces. All surfaces must be maintained on a regular basis. Surfaces of housing facilities.....that cannot be readily cleaned and sanitized, must be replaced when worn or soiled. ....

\*\*Two rooms housing primates were found to have several damaged areas along the walls. Large areas of peeling and chipped paint were observed by the support beams and along the base of the floors. These same rooms were previously noted as having deficiencies on the November 2003 IACUC facility inspection report. One of the rooms housing dogs was noted as having a large hole in the floor beneath one of the enclosures nearest the door. The surfaces should be maintained on a regular basis to promote proper husbandry practices as set forth in this section.

Correct by April 1, 2005

**Prepared By:**

*Dawn Barksdale*  
DAWN BARKSDALE, DVM, USDA, APHIS, Animal Care

**Title:** VETERINARY MEDICAL OFFICER, Inspector ID: 1062

**Date:**

SEP-01-2004

**Received By:**

(b)(6), (b)(7)c

**Title:**

**Date:**

SEP-01-2004